



Office of the Dy. Health Officer,
Narela Zone

No. DHO/NRZ/2022-23/624

Dated : 20/02/2023

School Health Certificate

1. Name of the School : Rahul Public School
2. Location : D-16, Rajeev Nagar Extn. Delhi-86
3. School Timing : 7:30 am to 1:30 pm
4. No. of staff : 27 (Male- 4 Female- 23)
5. No. of Students : Male 318
Female 202
520
6. No. of Rooms : 44
7. No. of Fans each in room : 4
8. No. of Urinals/Toilets : 22 (9 For Male, 9 For Female, 2 for staff, 2 for CWSN)
9. Drinking Water : Water Test Report (by Delhi Jal Board)

During the course of inspection, it is found that the school is functioning in good sanitary and hygienic condition.

Manager,
Rahul Public School
D-16, Rajeev Nagar Extn. Delhi-86

Dy. Health Officer
Narela Zone

Dy. Health Officer
Narela Zone North DMC

Principal
RAHUL PUBLIC SCHOOL
(Recognised & Affiliated to CBSE)
Rajiv Nagar Extn., Delhi-110086

Manager
RAHUL PUBLIC SCHOOL
(Recognised & Affiliated to CBSE)
Rajiv Nagar Extn., Delhi-110086



Delhi Jal Board
RAJIV NAGAR WATER WORKS

DELHI JAL BOARD

(GOVT. OF N.C.T DELHI)

ZONAL LABORATORY WATER WORKS HAIDERPUR

TEST REPORT

Water sample vide challan no 3861 dated 16.01.2023 collected from "Rahul Public School", Rajiv Nagar Extn., Delhi -110086"

S.No.	PARTICULARS	UNITS	SI
1	Date of Collection / Receipt		16/01/2023
2	Date of Analysis		10/02/2023
#	PHYSICAL EXAMINATION		
1	Colour	Hazen	Clear
2	Odour		No Obs.
3	Turbidity	N.T.U	2.01
4			7.39
5	Electrical Conductivity	Umhos/cm	290.00
6	Total Dissolved Solids	(mg/l)	-----
#	CHEMICAL EXAMINATION		
1	Phenolphthalein Alkalinity	(mg/l)	Nil
2	Total Alkalinity	(mg/l)	101.00
3	Corbonate Hardness	(mg/l)	102.00
4	Non-Carbonat Hardness	(mg/l)	29.00
5	Calcium as (Ca)	(mg/l)	35.10
6	Magmesium as (Mg)	(mg/l)	8.20
7	Ammonia (free & saline)	(mg/l)	Nil
8	Nitrite-Nitrogen (N)	(mg/l)	Nil
9	Nitrite NO ₃	(mg/l)	0.64
10	Sulphates (SO ₄)	(mg/l)	28.02
11	Chlorides	(mg/l)	10.10
12	Phosphates (PO ₄)	(mg/l)	Nil
13	Iron (Dissolved) (Fe)	(mg/l)	0.14
14	Fluorides (F)	(mg/l)	0.22
15	Cyanides (CN)	(mg/l)	Abst.
16	Potassium as (K)	(mg/l)	0.24
17	Sodium as Na	(mg/l)	----
18	% Sodium	(mg/l)	0.00
19	Residual Chlorine	(mg/l)	0.22
#	BACTERIOLOGICAL EXAMINATION		
1	Coli from per 100 ml at 37° C		0.00

Remarks: As per above tested parameters of SI, the water samples confirmed to I.S.: 10500-1993 Hence, it is fit for drinking purpose.

Asst. Chemist

Chemist Bacteriologist

A.C.W.A (HP)

C.W.A (N)

Principal

RAHUL PUBLIC SCHOOL
(Recognised & Affiliated to CBSE)
Rajiv Nagar Extn., Delhi-110086

MANAGER
RAHUL PUBLIC SCHOOL
(Recognised & Affiliated to CBSE)
Rajiv Nagar Extn., Delhi-110086